

6/27/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Amigos School

15 Upton Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062303-11	1st FI Gym Staff Bathroom CF-C	6/23/16	7:58 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	56	6/27/16	KMcInally
16062303-04	1st FI Rm 104 High Sink CF-C	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	30	6/27/16	KMcInally
16062303-16	2nd FI Library Sink CF-C	6/23/16	8:07 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	28	6/27/16	KMcInally
16062303-21	3rd FI Rm 306 Entrance Wall Sink CF-C	6/23/16	8:19 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	14	6/27/16	KMcInally
16062303-23	3rd FI Rm 306 Clock Wall Sink CF-C	6/23/16	8:18 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	13	6/27/16	KMcInally
16062303-18	2nd FI Teachers Lounge Mens Bathroom BF-C	6/23/16	8:13 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	13	6/27/16	KMcInally
16062303-07	1st FI Rm 106 CF-C	6/23/16	7:55 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	12	6/27/16	KMcInally
16062303-14	1st FI Nurse Office Sink NC	6/23/16	7:56 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	9	6/27/16	KMcInally
16062303-30	Basement AA Room CF-C	6/23/16	7:47 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	8	6/27/16	KMcInally
16062303-01	1st FI Rm 101 Sink CF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	7	6/27/16	KMcInally
16062303-06	1st FI Rm 104 Low Sink CF-C	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	6	6/27/16	KMcInally
16062303-36	Basement Kitchen Lift Sink KC	6/23/16	7:38 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	6	6/27/16	KMcInally
16062303-32	Basement Girls Bathroom Far Right BF-C	6/23/16	7:31 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	6	6/27/16	KMcInally
16062303-19	2nd FI Teachers Lounge Womens Bathroom BF-C	6/23/16	8:14 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	5	6/27/16	KMcInally
16062303-24	3rd FI Rm 308 CF-C	6/23/16	8:20 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	5	6/27/16	KMcInally
16062303-02	1st FI Rm 102 CF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	5	6/27/16	KMcInally
16062303-31	Basement Boys Bathroom Sink Far Right BF-C	6/23/16	7:46 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062303-20	2nd FI Hallway Staff Bathroom BF-C	6/23/16	8:16 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062303-15	2nd FI Bubbler DW	6/23/16	8:15 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062303-22	3RD FI Rm 306 Kitchenette KC	6/23/16	8:17 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E. Dowling

Date: 6/28/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

***Sampling Code:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurses Room Sink

6/27/2016

Cambridge School Department Lead in Tap Water Survey
 Cambridge Water Department Laboratory
 Mass. Certification # M-MA149
 E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Amigos School

15 Upton Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062303-08	1st Fl Rm 108 CF-C	6/23/16	7:58 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062303-13	1st Fl Nurse Bathroom NC- BF-C	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-09	1st Fl Rm 109 CF-C	6/23/16	8:07 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-37	Basement Staff Bathroom BF-C	6/23/16	8:19 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-03	1st Fl Rm 104 Bathroom Sink BF-C	6/23/16	8:18 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-33	Basement Kitchen Small Sink KH	6/23/16	8:13 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-05	1st Fl Rm 104 Bubbler DW	6/23/16	7:55 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-29	Basement Large Sink KH	6/23/16	7:56 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-12	1st Fl Main Entrance Bubbler DW	6/23/16	7:47 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-10	1st Fl Rm 110 CF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-27	Basement Kitchen Small Sink KC	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-17	2nd Fl Teachers Lounge CF-C	6/23/16	7:38 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-25	3rd Fl Hall Cooler WC-C	6/23/16	7:31 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-28	Basement Large Sink KC	6/23/16	8:14 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-26	3rd Fl Hall Cooler WC-H	6/23/16	8:20 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-34	Basement Kitchen Bathroom BF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-35	Basement Kitchen Lift Sink KH	6/23/16	7:46 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	ND	6/27/16	KMcInally
16062303-39	Basement Cafeteria Bottle Filler DW	6/23/16	8:16 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	ND	6/27/16	KMcInally
16062303-38	Basement Cafeteria Bubbler DW	6/23/16	8:15 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	ND	6/27/16	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form

and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: Ed Dowling

Date: 6/28/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

***Sampling Code:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurses Room Sink