

7/15/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Baldwin School

85 Oxford Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16070802-26	2nd Fl Rm. 204 Bubbler DW	7/8/2016	8:07 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	49	7/12/2016	KMcInally
16070802-10	Basement Kitchen Sink Middle KC	7/8/2016	7:32 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	25	7/12/2016	KMcInally
16070802-14	Basement Kitchen Lift Sink KC	7/8/2016	7:34 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	15	7/12/2016	KMcInally
16070802-31	2nd Fl Rm. 215 Bubbler DW	7/8/2016	8:01 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	13	7/14/2016	KMcInally
16070802-27	2nd Fl Rm. 208 Bubbler DW	7/8/2016	8:20 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	8	7/14/2016	KMcInally
16070802-32	2nd Fl Rm. 217 Bubbler DW	7/8/2016	8:02 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	6	7/14/2016	KMcInally
16070802-35	3rd Fl Staff Lounge Sink CF-C	7/8/2016	7:50 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	6	7/14/2016	KMcInally
16070802-25	2nd Fl Rm. 202 Bubbler DW	7/8/2016	8:05 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	5	7/12/2016	KMcInally
16070802-12	Basement Kitchen Far Right Sink KC	7/8/2016	7:31 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	5	7/12/2016	KMcInally
16070802-01	Basement Activity Rm. 008 CF-C	7/8/2016	7:36 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	4	7/12/2016	KMcInally
16070802-08	Basement Kitchen Sink Left KC	7/8/2016	7:33 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	4	7/12/2016	KMcInally
16070802-29	2nd Fl Rm. 212 Bubbler DW	7/8/2016	8:10 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	4	7/14/2016	KMcInally
16070802-28	2nd Fl Rm. 210 Bubbler DW	7/8/2016	8:25 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	4	7/14/2016	KMcInally

7/15/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Baldwin School

85 Oxford Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16070802-18	1st Fl Nurse Office Sink NC	7/8/2016	7:39 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	3	7/12/2016	KMcInally
16070802-21	1st Fl Rm. 102 Bubbler DW	7/8/2016	7:40 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	3	7/12/2016	KMcInally
16070802-30	2nd Fl Rm. 214 Bubbler DW	7/8/2016	8:15 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	3	7/14/2016	KMcInally
16070802-22	1st Fl Rm. 104 Bubbler DW	7/8/2016	7:40 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	1	7/12/2016	KMcInally
16070802-11	Basement Kitchen Sink Middle KH	7/8/2016	7:32 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-04	Basement Boys Bathroom Far Right Sink BF-C	7/8/2016	7:37 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-15	Basement Kitchen Lift Sink KH	7/8/2016	7:34 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-07	Basement Cafeteria Low Bubbler DW	7/8/2016	7:35 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-05	Basement Girls Bathroom Far Right Sink BF-C	7/8/2016	7:37 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-17	1st Fl Entrance Low Bubbler DW	7/8/2016	7:38 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-09	Basement Kitchen Sink Left KH	7/8/2016	7:33 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-13	Basement Kitchen Far Right Sink KH	7/8/2016	7:31 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-24	2nd Fl Low Bubbler DW	7/8/2016	8:00 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally

7/15/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
 Mass. Certification # M-MA149
 E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Baldwin School
 85 Oxford Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
 EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16070802-37	4th Fl Low Bubbler DW	7/8/2016	7:55 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/14/2016	KMcInally
16070802-33	3rd Fl High Bubbler DW	7/8/2016	7:47 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/14/2016	KMcInally
16070802-06	Basement Cafeteria High Bubbler DW	7/8/2016	7:35 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-36	4th Fl High Bubbler DW	7/8/2016	7:55 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/14/2016	KMcInally
16070802-20	1st Fl Sacramento St Low Bubbler DW	7/8/2016	7:42 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-19	1st Fl Sacramento St High Bubbler DW	7/8/2016	7:41 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-23	2nd Fl High Bubbler DW	7/8/2016	8:00 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-34	3rd Fl Low Bubbler DW	7/8/2016	7:47 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/14/2016	KMcInally
16070802-02	Basement Activity Rm High Bubbler DW	7/8/2016	7:36 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-03	Basement Activity Rm Low Bubbler DW	7/8/2016	7:36 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally
16070802-16	1st Fl Entrance High Bubbler DW	7/8/2016	7:38 AM	Kristen Middleton, Bobby Goodwin	Lead	ug/l	0.5	15	ND	7/12/2016	KMcInally

7/15/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School: **Baldwin School**
85 Oxford Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
------	-------------------	--------------	--------------	--------------	---------	-------	-----------------	--------------------------	------------------------	---------------	-------------

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E. Dowling

Date/Time 7/15/16 2:20A

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

*** Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink