

7/18/2016

**Cambridge School Department Lead in Tap Water Survey**

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

**Cambridgeport School**

89 Elm Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16070805-02	2nd Floor Rm. 100 CF-C	7/8/2016	6:27 AM	Mike Lane	Lead	ug/l	0.5	15	166	7/14/16	KMcInally
16070805-03	4th Floor Rm. 200 CF-C	7/8/2016	6:34 AM	Mike Lane	Lead	ug/l	0.5	15	37	7/15/16	KMcInally
16070805-04	4th Floor Rm. 202 CF-C	7/8/2016	6:37 AM	Mike Lane	Lead	ug/l	0.5	15	36	7/15/16	KMcInally
16070805-01	Basement Room L-6 Bubbler DW	7/8/2016	6:24 AM	Mike Lane	Lead	ug/l	0.5	15	35	7/15/16	KMcInally
16070805-05	4th Floor Rm. 204 CF-C	7/8/2016	6:42 AM	Mike Lane	Lead	ug/l	0.5	15	24	7/14/16	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form

and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling

Date/Time 7/18/16 5:11pm

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

**\* Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink