

7/28/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Cambridgeport School

89 Elm Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16071903-01	BSMT L-6 #1 Bubbler DW	7/19/2016	7:20 AM	Mike Lane	Lead	ug/l	0.5	15	27	7/25/2016	KMcInally
16071903-02	BSMT L-6 #2 Bubbler DW	7/19/2016	7:20 AM	Mike Lane	Lead	ug/l	0.5	15	18	7/25/2016	KMcInally
16071903-03	BSMT L-6 #3 Bubbler DW	7/19/2016	7:20 AM	Mike Lane	Lead	ug/l	0.5	15	15	7/25/2016	KMcInally
16071903-04	2nd Fl RM100 #1 CF-C	7/19/2016	7:06 AM	Mike Lane	Lead	ug/l	0.5	15	145	7/27/2016	KMcInally
16071903-05	2nd Fl Rm 100 #2 CF-C	7/19/2016	7:06 AM	Mike Lane	Lead	ug/l	0.5	15	81	7/25/2016	KMcInally
16071903-06	2nd Fl Rm 100 #3 CF-C	7/19/2016	7:06 AM	Mike Lane	Lead	ug/l	0.5	15	70	7/25/2016	KMcInally
16071903-07	4th Fl Rm 200 #1 CF-C	7/19/2016	7:10 AM	Mike Lane	Lead	ug/l	0.5	15	17	7/25/2016	KMcInally
16071903-08	4th Fl Rm 200 #2 CF-C	7/19/2016	7:10 AM	Mike Lane	Lead	ug/l	0.5	15	16	7/25/2016	KMcInally
16071903-09	4th Fl Rm 200 #3 CF-C	7/19/2016	7:10 AM	Mike Lane	Lead	ug/l	0.5	15	19	7/25/2016	KMcInally
16071903-10	4th Fl Rm 202 #1 CF-C	7/19/2016	7:13 AM	Mike Lane	Lead	ug/l	0.5	15	127	7/25/2016	KMcInally
16071903-11	4th Fl Rm 202 #2 CF-C	7/19/2016	7:13 AM	Mike Lane	Lead	ug/l	0.5	15	80	7/25/2016	KMcInally
16071903-12	4th Fl Rm 202 #3 CF-C	7/19/2016	7:13 AM	Mike Lane	Lead	ug/l	0.5	15	18	7/25/2016	KMcInally
16071903-13	4th Fl Rm 204 #1 CF-C	7/19/2016	7:15 AM	Mike Lane	Lead	ug/l	0.5	15	38	7/25/2016	KMcInally
16071903-14	4th Fl Rm 204 #2 CF-C	7/19/2016	7:15 AM	Mike Lane	Lead	ug/l	0.5	15	12	7/25/2016	KMcInally
16071903-15	4th Fl Rm 204 #3 CF-C	7/19/2016	7:15 AM	Mike Lane	Lead	ug/l	0.5	15	7	7/25/2016	KMcInally

7/28/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Cambridgeport School
89 Elm Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
------	-------------------	--------------	--------------	--------------	---------	-------	-----------------	--------------------------	------------------------	---------------	-------------

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling

Date/Time 7/28/16 SA

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

*** Sampling Codes:**

DW = Drinking Water Bubbler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurse's Room Sink