

8/23/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Cambridgeport School

89 Elm Street, Cambridge, MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16081804-01	2nd FI RM 100 #1 CF-C	8/18/2016	10:09 AM	Mike Lane	Lead	ug/l	0.5	15	2	8/22/2016	KMcInally
16081804-02	2nd FI Rm 100 #2 CF-C	8/18/2016	10:09 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/22/2016	KMcInally
16081804-03	4th FI RM 200 #1 CF-C	8/18/2016	10:15 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/22/2016	KMcInally
16081804-04	4th FI RM 200 #2 CF-C	8/18/2016	10:15 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/22/2016	KMcInally
16081804-05	4th FI RM 202 #1 CF-C	8/18/2016	10:21 AM	Mike Lane	Lead	ug/l	0.5	15	2	8/22/2016	KMcInally
16081804-06	4th FI RM 202 #2 CF-C	8/18/2016	10:21 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/22/2016	KMcInally
16081804-07	4th FI RM 204 #1 CF-C	8/18/2016	10:27 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/22/2016	KMcInally
16081804-08	4th FI RM 204 #2 CF-C	8/18/2016	10:27 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/22/2016	KMcInally
16081804-09	RM L-6 Bubbler #1 DW	8/18/2016	10:00 AM	Mike Lane	Lead	ug/l	0.5	15	9	8/22/2016	KMcInally
16081804-10	RM L-6 Bubbler #2 DW	8/18/2016	10:00 AM	Mike Lane	Lead	ug/l	0.5	15	8	8/22/2016	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

* Sampling Codes:

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: ED [Signature]

Date/Time 08/23/16 07:10A

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8