

9/13/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School: Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Graham & Parks School

Revised Technical Guidance

44 Linnaean Street, Cambridge MA

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16090207-01	1st Fl Gym Sink Sue's Area CF	9/2/2016	11:14 AM	Mike Lane	Lead	ug/l	0.5	15	63	9/8/2016	KMcInally
16090207-02	1st Fl Rm 101 BF-C	9/2/2016	10:52 AM	Mike Lane	Lead	ug/l	0.5	15	12	9/8/2016	KMcInally
16090207-03	1st Fl Rm 110 CF-C	9/2/2016	11:07 AM	Mike Lane	Lead	ug/l	0.5	15	2	9/8/2016	KMcInally
16090207-04	1st Fl Rm 111 Girls Room BF-C	9/2/2016	11:02 AM	Mike Lane	Lead	ug/l	0.5	15	3	9/8/2016	KMcInally
16090207-05	1st Fl Rm 116 CF-C	9/2/2016	10:46 AM	Mike Lane	Lead	ug/l	0.5	15	4	9/8/2016	KMcInally
16090207-06	2nd Fl Bathroom Far Right BF-C	9/2/2016	11:41 AM	Mike Lane	Lead	ug/l	0.5	15	22	9/8/2016	KMcInally
16090207-07	2nd Fl Library Sink CF-C	9/2/2016	10:34 AM	Mike Lane	Lead	ug/l	0.5	15	17	9/8/2016	KMcInally
16090207-08	2nd Fl Rm 212 CF-C	9/2/2016	10:30 AM	Mike Lane	Lead	ug/l	0.5	15	5	9/8/2016	KMcInally
16090705-01	1st Fl Gym Sink Jay CF-C	9/2/2016	11:20 AM	Mike Lane	Lead	ug/l	0.5	15	3	9/8/2016	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

*** Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E. DeWitt

Date/Time 9/13/16 10:52

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8