

6/10/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

Haggerty School

110 Cushing Street

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16060604-03	Kitchen Sink - Right KC	6/2/16	7:08 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	6	6/9/16	KMcInally
16060604-19	4th Floor Rm.402 CF-C	6/2/16	7:18 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	5	6/9/16	KMcInally
16060604-06	Basement Girls Bathroom - Right Sink BF-C	6/2/16	7:10 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	5	6/9/16	KMcInally
16060604-12	2nd Floor Rm.213 CF-C	6/2/16	7:14 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	4	6/9/16	KMcInally
16060604-17	3rd Floor Rm.306 CF-C	6/2/16	7:17 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	3	6/9/16	KMcInally
16060604-22	Teachers Lounge Sink (Cold) CF-C	6/3/16	6:20 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	3	6/9/16	KMcInally
16060604-11	2nd Floor Rm.212 CF-C	6/2/16	7:13 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	3	6/9/16	KMcInally
16060604-14	3rd Floor Library CF-C	6/2/16	7:15 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	3	6/9/16	KMcInally
16060604-16	3rd Floor Rm.305 CF-C	6/2/16	7:16 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	2	6/9/16	KMcInally
16060604-01	Nurses Office NS-C	6/2/16	7:07 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	2	6/9/16	KMcInally
16060604-08	1st Floor - RM.106 CF-C	6/2/16	7:12 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	2	6/9/16	KMcInally
16060604-21	Playground Bubbler High DW	6/2/16	7:20 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	1	6/9/16	KMcInally
16060604-20	Playground Bubbler Low DW	6/2/16	7:19 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	1	6/9/16	KMcInally
16060604-13	2nd Floor 3rd Grade Hallway Staff Bathroom BF-C	6/2/16	7:14 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	1	6/9/16	KMcInally
16060604-05	Basement Boys Bathroom - Right Sink BF-C	6/2/16	7:09 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	1	6/9/16	KMcInally
16060604-02	Kitchen Sink - Left KC	6/2/16	7:08 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-23	2nd Floor 3rd Grade Bubbler DW	6/3/16	6:21 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-04	Basement Boys Side Bubbler DW	6/2/16	7:09 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-26	Teachers Lounge Cooler DW-H	6/3/16	6:00 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-07	1st Floor - Kindergarten Hall Bubbler DW	6/2/16	7:11 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E. Dowling

Date: 6/10/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/10/2016

Cambridge School Department Lead in Tap Water Survey
 Cambridge Water Department Laboratory
 Mass. Certification # M-MA149
 E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Haggerty School
 110 Cushing Street

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
 Revised Technical Guidance
 EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16060604-15	3rd Floor 5th Grade Hallway Bubbler DW	6/2/16	7:15 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-09	1st Grade Hall Bubbler DW	6/2/16	7:12 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-10	2nd Floor 2nd Grade Hall Bubbler DW	6/2/16	7:13 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-18	3rd Floor 4th Grade Hallway Bubbler DW	6/2/16	7:18 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
16060604-25	Teachers Lounge Cooler DW-C	6/2/16	6:00 AM	Kristen Middleton, Joe Picanco	Lead	ug/L	0.5	15	ND	6/9/16	KMcInally
	*Sampling Code:										
	DW = Drinking Water Bubbler										
	WC = Water Cooler (Chiller Unit)										
	CF = Classroom faucet										
	KC = Kitchen Faucet-Cold										
	KH = Kitchen Faucet-Hot										
	EC = Home Economics Room-Cold										
	EH = Home Economics Room-Hot										
	EH = Home Economics Room-Hot										
	BF = Bathroom Faucet										
	NS = Nurses Room Sink										

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form
 and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling Date: 6/10/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8