

7/27/2016

Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

King Open School

359 Broadway, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16072203-04	Kitchen Small Sink KC	7/22/2016	7:22 AM	Mike Lane	Lead	ug/l	0.5	15	381	7/27/2016	KMcInally
16072203-05	Kitchen Small Sink KH	7/22/2016	7:22 AM	Mike Lane	Lead	ug/l	0.5	15	340	7/27/2016	KMcInally
16072203-08	2nd Fl Staff Bathroom BF-C	7/22/2016	7:35 AM	Mike Lane	Lead	ug/l	0.5	15	23	7/25/2016	KMcInally
16072203-03	Basement Inner Staff Bathroom BF-C	7/22/2016	7:25 AM	Mike Lane	Lead	ug/l	0.5	15	21	7/25/2016	KMcInally
16072203-07	1st Fl Rm 109 CF-C	7/22/2016	7:31 AM	Mike Lane	Lead	ug/l	0.5	15	10	7/25/2016	KMcInally
16072203-06	Kitchen BF-C	7/22/2016	7:23 AM	Mike Lane	Lead	ug/l	0.5	15	10	7/25/2016	KMcInally
16072203-01	Basement Rm K-3 High Sink CF-C	7/22/2016	7:28 AM	Mike Lane	Lead	ug/l	0.5	15	7	7/25/2016	KMcInally
16072203-02	Basement Art Rm Low Sink CF-C	7/22/2016	7:26 AM	Mike Lane	Lead	ug/l	0.5	15	6	7/25/2016	KMcInally

7/27/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
King Open School
359 Broadway, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
------	-------------------	--------------	--------------	--------------	---------	-------	-----------------	--------------------------	------------------------	---------------	-------------

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E. Downing

Date/Time 7/27/16 1:51 P

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

*** Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink