

8/10/2016

# Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

**Kennedy Longfellow School**

158 Spring Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16080204-17	3rd FL Rm 315 Bubbler DW	8/2/2016	7:21 AM	Mike Lane	Lead	ug/l	0.5	15	83	8/9/2016	KMcInally
16080204-06	2nd FL Rm 211 Bubbler DW	8/2/2016	6:50 AM	Mike Lane	Lead	ug/l	0.5	15	53	8/9/2016	KMcInally
16080204-13	3rd FL Rm 305 Bubbler DW	8/2/2016	7:08 AM	Mike Lane	Lead	ug/l	0.5	15	15	8/9/2016	KMcInally
16080204-18	3rd FL Rm 316 Bubbler DW	8/2/2016	7:18 AM	Mike Lane	Lead	ug/l	0.5	15	14	8/9/2016	KMcInally
16080204-15	3rd FL Rm 311 Bubbler DW	8/2/2016	7:13 AM	Mike Lane	Lead	ug/l	0.5	15	12	8/9/2016	KMcInally
16080204-14	3rd FL Rm 307 Bubbler DW	8/2/2016	7:10 AM	Mike Lane	Lead	ug/l	0.5	15	11	8/9/2016	KMcInally
16080204-01	2nd FL Rm 202 Bubbler DW	8/2/2016	6:37 AM	Mike Lane	Lead	ug/l	0.5	15	10	8/9/2016	KMcInally
16080204-03	2nd FL Rm 205 Bubbler DW	8/2/2016	6:42 AM	Mike Lane	Lead	ug/l	0.5	15	8	8/9/2016	KMcInally
16080204-10	3rd FL Rm 302 Bubbler DW	8/2/2016	7:33 AM	Mike Lane	Lead	ug/l	0.5	15	6	8/9/2016	KMcInally
16080204-04	2nd FL Rm 206 CF-C	8/2/2016	6:44 AM	Mike Lane	Lead	ug/l	0.5	15	6	8/9/2016	KMcInally
16080204-09	2nd FL Rm 213 Kitchen Sink Cold	8/2/2016	6:57 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-12	3rd FL Rm 304 Bubbler DW	8/2/2016	7:06 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-20	3rd FL Main Office CF-C	8/2/2016	7:43 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally

8/10/2016

Cambridge School Department Lead in Tap Water Survey  
Cambridge Water Department Laboratory  
Mass. Certification # M-MA149  
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:  
**Kennedy Longfellow School**  
158 Spring Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools  
Revised Technical Guidance  
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16080204-11	3rd FL Rm 303 Bubbler DW	8/2/2016	7:04 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-02	2nd FL Rm 203 CF-C	8/2/2016	6:40 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-08	2nd FL Rm 212 CF-C	8/2/2016	6:53 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-19	3rd FL Main Office Bubbler DW	8/2/2016	7:44 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-05	2nd FL Rm 210 Bubbler DW	8/2/2016	6:47 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/9/2016	KMcInally
16080204-16	3rd FL Rm 312 Bubbler DW	8/2/2016	7:25 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/9/2016	KMcInally
16080204-07	2nd FL Rm 211 CF-C	8/2/2016	6:49 AM	Mike Lane	Lead	ug/l	0.5	15	1	8/9/2016	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

**\* Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink

I certify under penalties of law that I am the person authorized to fill out this form  
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: EDowning

Date/Time 8/10/16 0642

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8