

8/19/2016

# Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

**Kennedy Longfellow School**

158 Spring Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16081103-01	1st Fl Room 101 Bubbler DW	8/11/2016	6:28 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/18/2016	KMcInally
16081103-02	1st Fl Room 104 Bubbler DW	8/11/2016	6:31 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/18/2016	KMcInally
16081103-03	1st Fl Room 109 Bubbler DW	8/11/2016	6:34 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/18/2016	KMcInally
16081103-04	2nd Fl Room 201 Bubbler DW	8/11/2016	6:38 AM	Mike Lane	Lead	ug/l	0.5	15	8	8/18/2016	KMcInally
16081103-05	2nd Fl Room 207 Bubbler DW	8/11/2016	6:40 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/18/2016	KMcInally
16081103-06	2nd Fl Room 209 Bubbler DW	8/11/2016	6:45 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/18/2016	KMcInally
16081103-07	2nd Fl Room 211 Bubbler Sample #1 DW	8/11/2016	6:47 AM	Mike Lane	Lead	ug/l	0.5	15	19	8/18/2016	KMcInally
16081103-08	2nd Fl Room 211 Bubbler Sample #2 DW	8/11/2016	6:48 AM	Mike Lane	Lead	ug/l	0.5	15	7	8/18/2016	KMcInally
16081103-09	2nd Fl Room 211 Bubbler Sample #3 DW	8/11/2016	6:49 AM	Mike Lane	Lead	ug/l	0.5	15	7	8/18/2016	KMcInally
16081103-10	2nd Fl Room 208 Bubbler DW	8/11/2016	6:42 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/18/2016	KMcInally
16081103-11	3rd Fl Room 305 Bubbler Sample #1 DW	8/11/2016	7:00 AM	Mike Lane	Lead	ug/l	0.5	15	12	8/18/2016	KMcInally
16081103-12	3rd Fl Room 305 Bubbler Sample #2 DW	8/11/2016	7:00 AM	Mike Lane	Lead	ug/l	0.5	15	6	8/18/2016	KMcInally
16081103-13	3rd Fl Room 305 Bubbler Sample #3 DW	8/11/2016	7:01 AM	Mike Lane	Lead	ug/l	0.5	15	4	8/18/2016	KMcInally
16081103-14	3rd Fl Room 309 CF-C	8/11/2016	7:09 AM	Mike Lane	Lead	ug/l	0.5	15	3	8/18/2016	KMcInally
16081103-15	3rd Fl Room 315 Bubbler Sample #1 DW	8/11/2016	7:10 AM	Mike Lane	Lead	ug/l	0.5	15	75	8/18/2016	KMcInally
16081103-16	3rd Fl Room 315 Bubbler Sample #2 DW	8/11/2016	7:11 AM	Mike Lane	Lead	ug/l	0.5	15	102	8/18/2016	KMcInally
16081103-17	3rd Fl Room 315 Bubbler Sample #3 DW	8/11/2016	7:11 AM	Mike Lane	Lead	ug/l	0.5	15	65	8/18/2016	KMcInally

8/19/2016

**Cambridge School Department Lead in Tap Water Survey**  
Cambridge Water Department Laboratory  
Mass. Certification # M-MA149  
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:  
**Kennedy Longfellow School**  
158 Spring Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools  
Revised Technical Guidance  
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
------	-------------------	--------------	--------------	--------------	---------	-------	-----------------	--------------------------	------------------------	---------------	-------------

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form  
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: *E. Dowling*

Date/Time 8/19/16 10:10A

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

**\* Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink