

9/13/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Kennedy Longfellow School
158 Spring Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results listed by sample number

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16090206-01	2nd FL Rm 211 Bubbler DW	9/2/2016	7:04 AM	Mike Lane	Lead	ug/l	0.5	15	7	9/8/2016	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

*** Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: 

Date/Time 9/13/16 10:53

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8