

6/8/2016

# Cambridge School Department Lead in Tap Water Survey

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

**Morse School**

40 Granite Street

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16060202-27	Room E3 DW	6/2/16	6:47 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	15	6/7/16	KMcInally
16060202-02	Kitchen Sink (Island Sink) KC	6/2/16	6:15 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	3	6/7/16	KMcInally
16060202-23	Girl's Bathroom E4-A BF-Far L	6/2/16	6:39 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	3	6/7/16	KMcInally
16060202-22	Room E3 CF-Cold	6/2/16	6:38 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	3	6/7/16	KMcInally
16060202-04	Kitchen Sink (Big Sink - L) KC	6/2/16	6:15 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	2	6/7/16	KMcInally
16060202-01	Kitchen Sink (Small Wall) KC	6/2/16	6:15 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	2	6/7/16	KMcInally
16060202-11	Romm A-6 Sink CF-C	6/2/16	6:21 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	2	6/7/16	KMcInally
16060202-03	Kitchen Sink (Big Sink - R) KC	6/2/16	6:15 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	2	6/7/16	KMcInally
16060202-16	Room B8 CF-C	6/2/16	6:28 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-12	Room A-6 Bubbler DW	6/2/16	6:22 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-21	Girl's Bathroom D8 BF-Far R	6/2/16	6:37 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-17	Room C3 CF-C	6/2/16	6:29 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-13	Mens Staff Bathroom B2 BF-C	6/2/16	6:24 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-24	Boy's Bathroom E4-C BF-Far L	6/2/16	6:42 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-14	Women's Staff Bathroom B2 BF-C	6/2/16	6:25 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-20	Boy's Bathroom D7 BF-Far R	6/2/16	6:34 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-29	Bathroom E10B BF-C	6/2/16	6:52 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-18	Room C3 DW	6/2/16	6:31 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-15	Room B8 DW	6/2/16	6:26 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	1	6/7/16	KMcInally
16060202-28	Bathroom E10A BF-C	6/2/16	6:51 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling

Date: 6/8/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/8/2016

**Cambridge School Department Lead in Tap Water Survey**  
 Cambridge Water Department Laboratory  
 Mass. Certification # M-MA149  
 E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:  
**Morse School**  
 40 Granite Street

Reference: 3Ts for Reducing Lead in Drinking Water in Schools  
 Revised Technical Guidance  
 EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16060202-05	Teacher's Lounge KC	6/2/16	6:17 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-25	E Wing Bubbler (Low) DW-L	6/2/16	6:45 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-08	Conference Room Bubbler (High) DW	6/2/16	6:19 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-26	E Wing Bubbler (High) DW-H	6/2/16	6:46 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-09	Conference Room Bubbler (Low) DW-L	6/2/16	6:19 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-10	A Wing Bubbler DW	6/2/16	6:20 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-19	D Wing Hall Bubbler (Low) DW-L	6/2/16	6:32 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-06	Teacher's Lounge WC-C	6/2/16	6:17 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
16060202-07	Teacher's Lounge WC-H	6/2/16	6:18 AM	Kristen Middleton, Dan Wright	Lead	ug/L	0.5	15	0	6/7/16	KMcInally
<b>*Sampling Code:</b> DW = Drinking Water Bubbler WC = Water Cooler (Chiller Unit) CF = Classroom faucet KC = Kitchen Faucet-Cold KH = Kitchen Faucet-Hot EC = Home Economics Room-Cold EH = Home Economics Room-Hot EH = Home Economics Room-Hot BF = Bathroom Faucet NS = Nurses Room Sink											

ug/L = micrograms per Liter or parts per billion  
 MDL = Method Detection Limit

I certify under penalties of law that I am the person authorized to fill out this form  
 and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling Date: 6/8/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8