

6/15/2016

**Cambridge School Department Lead in Tap Water Survey**  
Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter ( $\mu\text{g/L}$ ).

School:  
**Peabody School**  
70 Rindge Avenue

Reference: 3Ts for Reducing Lead in Drinking Water in Schools  
Revised Technical Guidance  
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16061302-18	1st Fl Sink - Mid KC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	7	6/14/16	KMchally
16061302-35	2nd Fl Rm 205 CF-C (Far Right)	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	2	6/14/16	KMchally
16061302-19	1st Fl Sink - Mid KH	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	2	6/14/16	KMchally
16061302-16	1st Fl Sink - Far left KC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	2	6/14/16	KMchally
16061302-20	1st Fl Sink - Far Right KH	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	2	6/14/16	KMchally
16061302-25	1st Fl Tilt Sink KC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	2	6/14/16	KMchally
16061302-22	1st Fl Hand Sink KC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-21	1st Fl Sink - Far Right KC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-43	2nd Fl Teachers Lounge CF-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-38	2nd Fl 6th Grade Girls Bathroom BF-C (Far Right)	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-26	1st Fl Main Office Staff Bathroom BF-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-23	1st Fl Prep Sink KC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-06	1st Fl Rm 160 CF-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	1	6/14/16	KMchally
16061302-37	2nd Fl 6th Grade Boys Bathroom BF-C Far Right	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally
16061302-17	1st Fl Sink - Far Left KH	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally
16061302-07	1st Fl Rm 154 Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally
16061302-34	1st Fl Teachers Lounge BF-C (Right Bathroom)	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally
16061302-24	1st Fl Prep Sink KH	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally
16061302-30	1st Fl (nurse) NC	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally
16061302-33	1st Fl Teachers Lounge BF-C (Left Bathroom)	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMchally

$\mu\text{g/L}$  = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: Z. Daniels

Date: 6/15/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/15/2016

**Cambridge School Department Lead in Tap Water Survey**  
Cambridge Water Department Laboratory  
Mass. Certification # M-MA149

School:  
**Peabody School**  
70 Rindge Avenue

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

Reference: 3Ts for Reducing Lead in Drinking Water in Schools  
Revised Technical Guidance  
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16061302-31	1st Fl Pub. Lib. Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-40	2nd Fl Staff Bathroom B-F-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-09	1st Fl Boys Bathroom Elevator B-F-C (Far Right)	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-10	1st Fl Girls Bathroom Elevator B-F-C (Far Right)	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-32	1st Fl Teachers Lounge C-F-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-11	1st Fl Boys Bathroom Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-08	1st Fl Rm 155 CF-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-01	1st Fl Rm 156 Bubbler DW	6/10/16	6:32 AM	Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-02	1st Fl Rm 157 CF-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-05	1st Fl Rm 159 Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-28	1st Fl Main Office WC-H	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-29	1st Fl Nurse Bathroom B-F-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-44	2nd Fl Teachers Lounge Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-04	1st Fl Rm 258 Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-12	1st Fl Girls Bathroom Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-42	2nd Fl Staff Cooler WC-H	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-14	1st Fl Comm. Wing Rm 142 Cooler WC-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-03	1st Fl Rm 157 Bubbler DW	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-41	2nd Fl Staff Cooler WC-C	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally
16061302-15	1st Fl Comm. Wing Cooler WC-H	6/10/16		Kristen Middleton, Chris Grassia	Lead	ug/L	0.5	15	ND	6/14/16	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: ZD Date: 6/15/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

City:\Water\Laboratory\School Lead Results\Pearlby School\20160615\_CWD\_Pearlby School Results Report.xls

6/15/2016

**Cambridge School Department Lead in Tap Water Survey**  
Cambridge Water Department Laboratory  
Mass. Certification # M-MA149  
E.E.P.A. Action Level: 15 Micrograms per Liter ( $\mu\text{g/L}$ ).

School:  
**Peabody School**  
10 Rindge Avenue

Reference: 3Ts for Reducing Lead in Drinking Water in Schools  
Revised Technical Guidance  
EPA 816-B-05-008 October 2006 Office of Water (4606)  
Results ranked highest to lowest

$\mu\text{g/L}$  = micrograms per Liter or parts per billion

MDL = Method Detection Limit

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E. Dowling Date: 6/15/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

City\Water\Laboratory\School\Lead Results\Peabody School\20160615\_CWD\_Peabody School Results Report.xls