

7/15/2016

**Cambridge School Department Lead in Tap Water Survey**

Cambridge Water Department Laboratory

Mass. Certification # M-MA149

E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:

**Tobin School**

197 Vassal Lane, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools

Revised Technical Guidance

EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sampling Location	Collect Date	Collect Time	Collected By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16070804-03	2nd Fl Rm.305 Bubbler DW	7/8/2016	7:26 AM	Kristen Middleton, Tommy Griffin, Mike	Lead	ug/l	0.5	15	22	7/15/2016	KMcInally
16070804-04	2nd Fl Rm.306 Bubbler DW	7/8/2016	7:27 AM	Kristen Middleton, Tommy Griffin, Mike	Lead	ug/l -	0.5	15	11	7/15/2016	KMcInally
16070804-02	2nd Fl Girls Bathroom Sink Far Right BF-C	7/8/2016	7:20 AM	Kristen Middleton, Tommy Griffin, Mike	Lead	ug/l	0.5	15	2	7/15/2016	KMcInally
16070804-01	2nd Fl Boys Bathroom Far Right Sink BF-C	7/8/2016	7:22 AM	Kristen Middleton, Tommy Griffin, Mike	Lead	ug/l	0.5	15	2	7/15/2016	KMcInally

ug/L = micrograms per Liter or parts per billion

MDL = Method Detection Limit

ND = Not Detected

**\* Sampling Codes:**

DW = Drinking Water Bubbler

WC = Water Cooler (Chiller Unit)

CF = Classroom faucet

KC = Kitchen Faucet-Cold

KH = Kitchen Faucet-Hot

EC = Home Economics Room-Cold

EH = Home Economics Room-Hot

BF = Bathroom Faucet

NS = Nurse's Room Sink

I certify under penalties of law that I am the person authorized to fill out this form

and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling

Date/Time 7/15/16 09:45A

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8