6/27/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Amigos School
15 Upton Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062303-11	1st Fl Gym Staff Bathroom CF-C	6/23/16	7:58 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	56	6/27/16	KMclnally
16062303-04	1st Fl Rm 104 High Sink CF-C	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	30	6/27/16	KMclnally
16062303-16	2nd Fl Library Sink CF-C	6/23/16	8:07 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	28	6/27/16	KMclnally
16062303-21	3rd Fl Rm 306 Entrance Wall Sink CF-C	6/23/16	8:19 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	14	6/27/16	KMclnally
16062303-23	3rd Fl Rm 306 Clock Wall Sink CF-C	6/23/16	8:18 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	13	6/27/16	KMclnally
16062303-18	2nd Fl Teachers Lounge Mens Bathroom BF-C	6/23/16	8:13 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	13	6/27/16	KMclnally
16062303-07	1st Fl Rm 106 CF-C	6/23/16	7:55 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	12	6/27/16	KMclnally
16062303-14	1st Fl Nurse Office Sink NC	6/23/16	7:56 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	9	6/27/16	KMclnally
16062303-30	Basement AA Room CF-C	6/23/16	7:47 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	8	6/27/16	KMclnally
16062303-01	1st Fl Rm 101 Sink CF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	7	6/27/16	KMclnally
16062303-06	1st FL Rm 104 Low Sink CF-C	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	6	6/27/16	KMclnally
16062303-36	Basement Kitchen Lift Sink KC	6/23/16	7:38 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	6	6/27/16	KMclnally
16062303-32	Basement Girls Bathroom Far Right BF-C	6/23/16	7:31 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	6	6/27/16	KMclnally
16062303-19	2nd Fl Teachers Lounge Womens Bathroom BF-C	6/23/16	8:14 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	5	6/27/16	KMclnally
16062303-24	3rd Fl Rm 308 CF-C	6/23/16	8:20 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	5	6/27/16	KMclnally
16062303-02	1st Fl Rm 102 CF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	5	6/27/16	KMclnally
16062303-31	Basement Boys Bathroom Sink Far Right BF-C	6/23/16	7:46 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMclnally
16062303-20	2nd Fl Hallway Staff Bathroom BF-C	6/23/16	8:16 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMclnally
16062303-15	2nd Fl Bubbler DW	6/23/16	8:15 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMclnally
16062303-22	3RD Fl Rm 306 Kitchenette KC	6/23/16	8:17 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMclnally

ug/L = micrograms per Liter or parts per billion
MDL = Method Detection Limit
ND = Not Detected

***Sampling Code:**
DW = Drinking Water Bubler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurses Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling Date: 6/28/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/27/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Amigos School
15 Upton Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062303-08	1st Fl Rm 108 CF-C	6/23/16	7:58 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062303-13	1st Fl Nurse Bathroom NC- BF-C	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-09	1st Fl Rm 109 CF-C	6/23/16	8:07 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-37	Basement Staff Bathroom BF-C	6/23/16	8:19 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-03	1st Fl Rm 104 Bathroom Sink BF-C	6/23/16	8:18 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-33	Basement Kitchen Small Sink KH	6/23/16	8:13 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062303-05	1st Fl Rm 104 Bubbler DW	6/23/16	7:55 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-29	Basement Large Sink KH	6/23/16	7:56 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-12	1st Fl Main Entrance Bubbler DW	6/23/16	7:47 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-10	1st Fl Rm 110 CF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062303-27	Basement Kitchen Small Sink KC	6/23/16	8:00 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-17	2nd Fl Teachers Lounge CF-C	6/23/16	7:38 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-25	3rd Fl Hall Cooler WC-C	6/23/16	7:31 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-28	Basement Large Sink KC	6/23/16	8:14 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-26	3rd Fl Hall Cooler WC-H	6/23/16	8:20 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-34	Basement Kitchen Bathroom BF-C	6/23/16	8:05 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	1	6/27/16	KMcInally
16062303-35	Basement Kitchen Lift Sink KH	6/23/16	7:46 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	ND	6/27/16	KMcInally
16062303-39	Basement Cafeteria Bottle Filler DW	6/23/16	8:16 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	ND	6/27/16	KMcInally
16062303-38	Basement Cafeteria Bubbler DW	6/23/16	8:15 AM	Kristen Middleton, Eric Bergren	Lead	ug/L	0.5	15	ND	6/27/16	KMcInally

ug/L = micrograms per Liter or parts per billion
MDL = Method Detection Limit
ND = Not Detected

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling Date: 6/28/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

***Sampling Code:**
DW = Drinking Water Bubler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurses Room Sink