6/29/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Graham & Parks School
44 Linnaean Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062403-25	1st Fl Rm. 111 BF-C	6/24/16	6:48 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1151	6/28/16	KMcInally
16062403-03	1st Fl Rm. 101 BF-C	6/24/16	7:28 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	444	6/28/16	KMcInally
16062403-73	2nd Fl Boys Bathroom Far Right Sink BF-C	6/24/16	8:05 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	28	6/28/16	KMcInally
16062403-39	1st Fl Gym Sink Sue CF-C	6/24/16	7:05 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	27	6/28/16	KMcInally
16062403-75	2nd Fl Library Sink CF-C	6/24/16	8:05 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	21	6/28/16	KMcInally
16062403-27	1st Fl Rm. 116 CF-C	6/24/16	7:45 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	21	6/28/16	KMcInally
16062403-38	1st Fl Gym Sink Jay CF-C	6/24/16	7:04 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	21	6/28/16	KMcInally
16062403-53	2nd Fl Rm. 212 CF-C	6/24/16	8:09 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	19	6/28/16	KMcInally
16062403-22	1st Fl Rm. 110 CF-C	6/24/16	6:52 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	12	6/28/16	KMcInally
16062403-18	1st Fl Rm. 107 BF-C	6/24/16	6:47 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	9	6/27/16	KMcInally
16062403-66	2nd Fl Rm. 223 CF-C	6/24/16	8:01 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	8	6/28/16	KMcInally
16062403-50	1st Fl Teachers Lounge BF-C	6/24/16	7:47 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	8	6/28/16	KMcInally
16062403-15	1st Fl Rm. 106 CF-C	6/24/16	6:45 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	8	6/27/16	KMcInally
16062403-37	1st Fl Girls Bathroom Far Right Sink BF-C	6/24/16	6:55 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	8	6/28/16	KMcInally
16062403-16	1st Rm. 106 BF-C	6/24/16	6:47 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	7	6/27/16	KMcInally
16062403-14	1st Fl Rm. 105 CF-C	6/24/16	7:26 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	6	6/27/16	KMcInally
16062403-06	1st Fl Rm. 102 BF-C	6/24/16	7:35 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	6	6/27/16	KMcInally
16062403-55	2nd Fl Rm. 213 CF-C	6/24/16	8:10 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	6	6/28/16	KMcInally
16062403-72	2nd Fl Rm. 226 BF-C	6/24/16	8:00 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	6	6/28/16	KMcInally
16062403-24	1st Fl Rm. 111 CF-C	6/24/16	6:48 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	6	6/28/16	KMcInally

ug/L = micrograms per Liter or parts per billion
MDL = Method Detection Limit
ND = Not Detected

***Sampling Code:**
DW = Drinking Water Bubler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurses Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowlin S Date: 6/29/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/29/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Graham & Parks School
44 Linnaean Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062403-09	1st Fl Rm. 104 BF-C	6/24/16	6:48 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	6	6/27/16	KMcInally
16062403-65	2nd Fl Rm. 221 CF-C	6/24/16	7:28 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	5	6/28/16	KMcInally
16062403-68	2nd Fl Rm. 224 CF-C	6/24/16	8:05 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	5	6/28/16	KMcInally
16062403-63	2nd Fl Rm. 220 CF-C	6/24/16	7:05 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-70	2nd Fl Rm. 225 CF-C	6/24/16	8:05 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-11	1st Fl Rm. 104 CF-C	6/24/16	7:45 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062403-62	2nd Fl Rm. 217 CF-C	6/24/16	7:04 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-74	2nd Fl Girls Bathroom Far Right Sink BF-C	6/24/16	8:09 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-10	1st Fl Rm. 104 Bubbler DW	6/24/16	6:52 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062403-21	1st Fl Rm. 110 Bubbler DW	6/24/16	6:47 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-57	2nd Fl Rm. 214 CF-C	6/24/16	8:01 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-41	1st Fl Kitchen Staff Bathroom BF-C	6/24/16	7:47 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-02	1st Fl Rm. 101 CF-C	6/24/16	6:45 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062403-19	1st Fl Rm/ 107 CF-C	6/24/16	6:55 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/27/16	KMcInally
16062403-61	2nd Fl Rm. 216 CF-C	6/24/16	6:47 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	4	6/28/16	KMcInally
16062403-23	1st Fl Rm. 110 BF-C	6/24/16	7:26 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/28/16	KMcInally
16062403-44	1st Fl Main Office BF-C	6/24/16	7:35 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/28/16	KMcInally
16062403-17	1st Rm. 106 Class Bubbler DW	6/24/16	8:10 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062403-45	1st Fl Middle Sink KC	6/24/16	8:00 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/28/16	KMcInally
16062403-35	1st Fl Far Right Sink KC	6/24/16	6:48 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/28/16	KMcInally

ug/L = micrograms per Liter or parts per billion
MDL = Method Detection Limit
ND = Not Detected

***Sampling Code:**
DW = Drinking Water Bubler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurses Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowlin Date: 5/29/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/29/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Graham & Parks School
44 Linnaean Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest to lowest

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date	Analyzed By
16062403-05	1st Fl Rm. 102 CF-C	6/24/16	7:35 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/27/16	KMcInally
16062403-49	1st Fl Stand Alone Sink KC	6/24/16	7:15 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/28/16	KMcInally
16062403-31	1st Fl Boys Bathroom Sink Far Right BF-C	6/24/16	6:54 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	3	6/28/16	KMcInally
16062403-43	1st Fl Main Entrance Bubbler DW	6/24/16	7:45 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-08	1st Fl Rm. 103 CF-C	6/24/16	7:20 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062403-26	1st Fl Rm. 111 Bubbler DW	6/24/16	6:48 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-48	1st Fl Nurse NC	6/24/16	7:45 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-13	1st Fl Rm. 105 BF-C	6/24/16	7:26 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062403-64	2nd Fl Rm. 221 Bubbler DW	6/24/16	7:37 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-54	2nd Fl Rm. 212 Bubbler DW	6/24/16	8:09 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-67	2nd Fl Rm. 223 Bubbler DW	6/24/16	8:03 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-33	1st Fl Far Left Sink KC	6/24/16	7:15 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-20	1st Fl Rm. 107 Bubbler DW	6/24/16	6:46 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062403-60	2nd Fl Rm. 216 Bubbler DW	6/24/16	8:11 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-56	2nd Fl Rm. 213 Bubbler DW	6/24/16	8:10 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-12	1st Fl Rm. 105 Bubbler DW	6/24/16	7:26 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062403-04	1st Fl Rm. 102 Bubbler DW	6/24/16	7:35 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/27/16	KMcInally
16062403-58	2nd Fl Rm. 215 CF-C	6/24/16	8:15 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-71	2nd Fl Rm. 225 Bubbler DW	6/24/16	8:03 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	2	6/28/16	KMcInally
16062403-07	1st Fl Rm. 103 Bubler DW	6/24/16	7:20 AM	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1	6/27/16	KMcInally

ug/L = micrograms per Liter or parts per billion
MDL = Method Detection Limit
ND = Not Detected

***Sampling Code:**
DW = Drinking Water Bubler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurses Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: E Dowling Date: 6/29/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8

6/29/2016

Cambridge School Department Lead in Tap Water Survey
Cambridge Water Department Laboratory
Mass. Certification # M-MA149
E.P.A. Action Level: 15 Micrograms per Liter (ug/L).

School:
Graham & Parks School
44 Linnaean Street, Cambridge MA

Reference: 3Ts for Reducing Lead in Drinking Water in Schools
Revised Technical Guidance
EPA 816-B-05-008 October 2006 Office of Water (4606)

Results ranked highest t

Lab#	Sample Location/Sampling Code	Collect Date	Collect Time	Collect By	Test ID	Units	Calc MDL - ug/L	Lead Action Level - ug/L	Reported Result - ug/L	Analysis Date
16062403-52	1st Fl Teachers Lounge WC-H	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1.396	42549
16062403-47	1st Fl Nurse BF-C	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1.338	42549
16062403-69	2nd Fl Rm. 224 Bubbler DW	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1.262	42549
16062403-01	1st Fl Rm. 101 Bubbler DW	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1.214	42548
16062403-30	1st Fl AA Room CF-C	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	1.106	42549
16062403-28	1st Fl Rm. 220 Bubbler DW	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.9342	42549
16062403-36	1st Fl Far right Sink KH	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.8992	42549
16062403-46	1st Fl Middle Sink KH	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.7995	42549
16062403-42	1st Fl Kitchen Stand Alone Sink KH	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.6549	42549
16062403-29	1st Fl CF-C	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.6403	42549
16062403-34	1st Fl Far Left Sink KH	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.607	42549
16062403-59	2nd Fl Rm. 215 Bubbler DW	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	0.5525	42549
16062403-32	1st Fl Outside Cafeteria Bubbler DW	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	ND	42549
16062403-51	1st Fl Teackers Lounge WC-C	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	ND	42549
16062403-40	1st Fl Hydroboost DW	6/24/16	1/0/00	Kristen Middleton, Lance Walker	Lead	ug/L	0.5	15	ND	42549

ug/L = micrograms per Liter or parts per billion
MDL = Method Detection Limit
ND = Not Detected

***Sampling Code:**
DW = Drinking Water Bubler
WC = Water Cooler (Chiller Unit)
CF = Classroom faucet
KC = Kitchen Faucet-Cold
KH = Kitchen Faucet-Hot
EC = Home Economics Room-Cold
EH = Home Economics Room-Hot
EH = Home Economics Room-Hot
BF = Bathroom Faucet
NS = Nurses Room Sink

I certify under penalties of law that I am the person authorized to fill out this form
and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Director: S Dowling Date: 6/29/16

Massachusetts Laboratory Certification Number: M-MA149

Lead Testing Method: EPA Method 200.8